

Emission Test Certificate

Friday, March 21st, 2014

Supplier: Knauf Plasterboard Pty Ltd (31 Military Rd, Matraville NSW 2036)

Sample Description: TruRock

Date Tested: March 2014 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

<p>Green Building Council of Australia Green Star Office Design v3 IEQ-13</p>	<p>TruRock</p>
<p>Total Volatile Organic Compound emission rate: <500 ug/m²/hr</p>	<p>16 ug/m²/hr</p>
<p>Ecospecifier GreenTag Certification Program</p>	<p>TruRock</p>
<p>Total Volatile Organic Compound emission rate: <500 ug/m²/hr</p>	<p>16 ug/m²/hr</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant

CV140301