

VOC Content Test Certificate

Monday February 20th, 2012

Manufacturer: Knauf Plasterboard (31 Military Rd, Matraville NSW 2036)

Date Tested: *October 2008 (Tested by FORAY Laboratories – NATA Accreditation 1231)

^April 2011 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 303-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

<p align="center">Specification</p> <p>Green Building Council of Australia Green Star Office Design V3 IEQ-13</p>	<p>MastaSmooth*, MastaRapid* MastaLongset*, MastaLite* MastaFinish*, MastaCove 75* MastaGrip*, MastaCove 45*, MastaBond*, MastaBlock* MastaBase*, MastaFix 20* DecoMachine^, MastaGlide^, MastaLite^</p>
<p>Dry Wall and Panel Adhesive 50 grams per Litre as VOC content per material</p>	<p><50 grams per Litre as VOC content per material</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Anne Saletti
BNanotech/BSc(Hons)
Consultant

CV111109a