

VOC Content Test Certificate

Tuesday, 04th February 2020

Supplier: Knauf Plasterboards Pty Ltd (31 Military Road, Matraville, NSW, 2036, Australia).

Sample Description: Knauf Aquapanel / Permarock Joint Adhesive

Date Tested: February 2020 (Tested by FORAY Laboratories – NATA Accreditation 1231)


Test Method: ASTM D3690-05 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960 as detailed for paints as well as South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:

<p>Specification</p> <p>Green Building Council of Australia</p> <p>Green Star Design & As Built V1.3 13.1.1</p> <p>Green Star Interiors V1.3 12.1.1B</p>	<p>Knauf Aquapanel /</p> <p>Permarock Joint</p> <p>Adhesive</p>
<p>General Purpose Adhesives and Sealants: 50 grams per Litre as VOC content per material</p>	<p>8 gram per Litre as VOC content per material</p>
<p><i>We hereby certify Knauf Aquapanel / Permarock Joint Adhesive is below the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia</i></p>	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
BE (Chem. Eng.)
Consultant



Dale Duncan
BSc (Hons)
Consultant

V2002003A